



If you do not want to run a separate circuit you can tie your alarm/buzzer/light into 5&N provide a 120V output when the flow switch closes.

<p><u>OPTIONS</u></p>	<p><u>SYSTEM INFORMATION</u></p> <p>CAT NO: <u>INPCI-3G2</u></p> <p><u>240 V</u> <u>3</u> HP <u>1</u> PH <u>60</u> HZ</p> <p>CONTROL VOLTAGE: <u>120</u> V</p> <p>IC <u>N/A</u> KA SYM AT <u>N/A</u> V MAX</p> <p>ENCLOSURE TYPE: <u>NEMA 1</u></p>	 	<p><u>CUSTOMER INFORMATION</u></p> <p>PROJECT: _____</p> <p>CUSTOMER: <u>R.T. STEARNS</u></p> <p>CUSTOMER #: _____</p>
-----------------------	---	----------	--

<p>ROUTING</p> <p>1 - JOB FILE</p> <p>2 - PRODUCTION</p>	<p><small>EATON CORPORATION - CONFIDENTIAL AND PROPRIETARY NOTICE TO PERSONS RECEIVING THIS DOCUMENT AND/OR TECHNICAL INFORMATION: THIS DOCUMENT, INCLUDING THE DRAWING AND INFORMATION CONTAINED THEREON, IS CONFIDENTIAL AND IS THE EXCLUSIVE PROPERTY OF EATON CORPORATION, AND IS MERELY ON LOAN AND SUBJECT TO RECALL BY EATON AT ANY TIME BY TAKING POSSESSION OF THIS DOCUMENT. THE RECIPIENT ACKNOWLEDGES AND AGREES THAT THIS DOCUMENT CANNOT BE USED IN ANY MANNER ADVERSE TO THE INTERESTS OF EATON AND THAT NO PORTION OF THIS DOCUMENT MAY BE COPIED OR OTHERWISE REPRODUCED WITHOUT THE PRIOR WRITTEN CONSENT OF EATON. IN THE CASE OF CONFLICTING CONTRACTUAL PROVISIONS, THIS NOTICE SHALL GOVERN THE STATUS OF THIS DOCUMENT.</small></p>	<p>DFTR DESS. DATE</p> <p>KL 09/20/12</p> <p>APPD APPR. DATE</p> <p>KL 09/20/12</p> <p>APPD APPR. DATE</p>	<p>LVCA CALGARY, AB</p> <p>LIFE SAFETY PANELS</p> <p>WIRING DIAGRAM</p>	
<p>PRODUCT CODE</p> <p>CODE PRODUIT</p>	<p>REVISION</p> <p>2</p>	<p>DWG SIZE /</p> <p>A</p>	<p>G.O. DWG</p> <p>16BU</p>	<p>PAGE</p> <p>1 OF 1</p>